

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
District Disaster Response & Fire Officer
Andhra Pradesh, Kurnool

To:
The District Educational Officer,
Kurnool

File No: 27848/KRN/DFO/2025, Date:06/01/2026

Occupancy NoC RC Number: 990/A2/KNL/2016

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Satyam Educational Society, D.No.81-248-1, Kasturi Nagar Kurnool, represented by Management, Satyam Educational Society. represented by Management, Sy.No.348 & 555, Pyalapurthy Village & Gram Panchayath, Kodumur Mandal, Kurnool District** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 990/A2/KNL/2016, Dt.26/04/2016
 4. Renewal NOC For Occupancy 990/A2/KNL/2016, Dt.11/06/2020
 5. Online Application for Renewal NOC of Management, Satyam Educational Society. represented by Management, Sy.No.348 & 555, Pyalapurthy Village & Gram Panchayath, Kodumur Mandal, Kurnool District - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 03-01-2026.

-- x --

The Management of Satyam Educational Society, D.No.81-248-1, Kasturi Nagar, Kurnool, represented by Management, Satyam Educational Society. represented by Management, Sy.No.348 & 555, Pyalapurthy Village & Gram Panchayath, Kodumur Mandal, Kurnool District has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.9530/- vide challan No. 91119202612025, Dated 16/07/2025 at SBI, Kurnool.

Satyam Educational Society

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Management Satyam Educational Society. represented by Management, Sy.No.348 & 555, Pyalapurthy Village & Gram Panchayath, Kodumur Mandal, Kurnool District**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.

4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.
---	---	--	--

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 26/04/2025 to 25/04/2030.
5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.


6. Challan Info:

Challan Number	Challan Date	Challan Amount
91119202612025	2025-07-16	9530

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

- 1). The Renewal NOC valid for five years, subject to establish the external staircase within three months according to the affidavit submitted by the management from the date of issuing renewal NOC.
- 2). The management has remitted fire precautionary renewal fee for Rs.9530/- vide challan No.9119202612025, Dt. 16.07.2025 and Rs.38100/- vide challan No.91311519702025, Dt. 06.01.2025 for five years.
- 3). This Renewal NOC is issued from Fire Safety Point of view only basing on recommendation of the inspection Committee and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.
- 4). The Management has to maintain Fire Safety Measures and other installations in good working condition at all times and the responsibility of Fire Fighting equipment maintenance lies with the management as seen & tested by the committee at the time of inspection.
- 5). This Renewal NOC is valid for Five years only and it is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per G.O.Ms.No.178, Home (Prisons & Fire) Department. Dt.17-12-2025 two months before expire of this No Objection Certificate.
- 6). The stakeholders shall submit and upload an Annual Fire Safety Compliance Report in the prescribed proforma on the designated portal to ensure continued adherence to fire safety norms. The Department shall conduct random inspections through its officers to verify compliance.

Your Sincerely,


District Disaster Response & Fire Officer,
Kurnool District

Copy to Management Management, Satyam Educational Society, D.No.81-248-1, Kasturi Nagar, Kurnool
Copy to Assistant District Fire Officer Concerned
Copy to Station Fire Officer Concerned